


CONFINED SPACE ENTRY PERMIT

Issue Date: 5/18/10 School Name: Madison
Issue Time: 9:00 AM Confined Space: Boiler T
Expiration Date: 5/18/10 Entry Personnel: Steve Keller
Expiration Time: 9:30 AM Standby Personnel: Jamie Nixon

NOTE: DURATION OF PERMIT IS NOT TO EXCEED 8 HOURS FOR ENTRY INTO A CONFINED SPACE.

Atmospheric Checks Time: _____ am / pm
Oxygen: 20.9 % (19.5%-22.5%)
Combustible: 0 % L.E.L. (<10% CH₄)
Toxic: 0 ppm (<10% H₂S)
Carbon Monoxide: 0 ppm (<35ppm)

Tester's Name and Signature: Jamie Nixon 

<u>Isolation of Pumps or Lines</u>	Yes	No	N/A
Pumps or lines blocked, blanked, or disconnected	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

<u>Ventilation</u>	Yes	No	N/A
Mechanical	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Natural ventilation only	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>


Atmospheric Checks after Isolation and/or Ventilation (if necessary)

Oxygen: _____ % (19.5%-22.5%)
Combustible: _____ % L.E.L. (<10% CH₄)
Toxic: _____ ppm (<10% H₂S)
Carbon Monoxide: _____ ppm (<35ppm)

Tester's Name and Signature: _____

<u>Equipment</u>	Yes	No	N/A
Calibrated 4-gas meter	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Safety harness/lifelines	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper PPE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mechanical/retrieval devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical tools/lighting/non-spark tools	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

We have reviewed the work authorized by this permit and the information contained herein. Written instructions and safety procedures have been received and reviewed. This permit is not valid unless all appropriate items are completed and understood.


Prepared by: Jamie Nixon (print)  (sign)
Approved by: _____ (print) _____ (sign)

CONFINED SPACE ENTRY PERMIT

Issue Date: 5/18/10 School Name: Madison
 Issue Time: 9:15 Am Confined Space: Boiler II
 Expiration Date: 5/19/10 Entry Personnel: Steve Kellar
 Expiration Time: 9:15 Am Standby Personnel: Jamie Nixon

NOTE: DURATION OF PERMIT IS NOT TO EXCEED 8 HOURS FOR ENTRY INTO A CONFINED SPACE.

Atmospheric Checks Time: _____ am / pm
 Oxygen: 20.9 % (19.5%-22.5%)
 Combustible: 0 % L.E.L. (<10% CH₄)
 Toxic: 0 ppm (<10% H₂S)
 Carbon Monoxide: 0 ppm (<35ppm)

Tester's Name and Signature: Jamie Nixon 

<u>Isolation of Pumps or Lines</u>	Yes	No	N/A
Pumps or lines blocked, blanked, or disconnected	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

<u>Ventilation</u>	Yes	No	N/A
Mechanical	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Natural ventilation only	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>


Atmospheric Checks after Isolation and/or Ventilation (if necessary)

Oxygen: _____ % (19.5%-22.5%)
 Combustible: _____ % L.E.L. (<10% CH₄)
 Toxic: _____ ppm (<10% H₂S)
 Carbon Monoxide: _____ ppm (<35ppm)

Tester's Name and Signature: _____

<u>Equipment</u>	Yes	No	N/A
Calibrated 4-gas meter	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Safety harness/lifelines	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper PPE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mechanical/retrieval devices	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical tools/lighting/non-spark tools	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

We have reviewed the work authorized by this permit and the information contained herein. Written instructions and safety procedures have been received and reviewed. This permit is not valid unless all appropriate items are completed and understood.

Prepared by: Jamie Nixon (print)  (sign)
 Approved by: _____ (print) _____ (sign)