



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 26 Jan 2021
Date Sampled: 20 Jan 2021
Time Sampled: 7:30
Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A3440	SCT 1 C107G KITCHEN SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3441	SCT 2 C110B SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3442	SCT 3 KITCHEN SINK NEAR SCALE SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3443	SCT 4 ISLAND KITCHEN SINK N SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3444	SCT 5 ISLAND KITCHEN SINK S SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3445	SCT 6 WARE WASHING E SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3446	SCT 7 WARE WASHING W SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3447	SCT 8 SERVING AREA W SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3449	SCT 9 SERVING AREA W SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3450	SCT 10 SERVING AREA W SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 26 Jan 2021
Date Sampled: 20 Jan 2021
Time Sampled: 7:30
Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A3451	SCT 11 SERVING AREA E SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3452	SCT 12 SERVING AREA E SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3453	SCT 13 C110E SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3454	SCT 14 CAFETERIA DRINKING FOUNTAIN DF	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3455	SCT 15 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3456	SCT 16 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3457	SCT 17 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3458	SCT 18 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3459	SCT 19 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3460	SCT 20 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 26 Jan 2021
Date Sampled: 20 Jan 2021
Time Sampled: 7:30
Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A3461	SCT 21 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3462	SCT 22 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3463	SCT 23 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3464	SCT 24 C105 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3465	SCT 25 D116 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3466	SCT 26 MAIN ENTRANCE DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3467	SCT 27 NURSES OFFICE SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3468	SCT 28 POOL HALLWAY DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3469	SCT 29 A101Q SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3470	SCT 30 B102	< 0.5 ug/L	15.0	29 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

JOSH BAUMANN
 RESOURCE TRAINING & SOLUTIONS
 137 23RD ST S
 SARTELL MN 56377

Work Order #: 12-4790
 Account #: 019442

Date Received: 26 Jan 2021
 Date Sampled: 20 Jan 2021
 Time Sampled: 7:30
 Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
	SINK				
21-A3471	SCT 31 B111 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3472	SCT 32 LOCKER ROOM HALL DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3473	SCT 33 B120 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3474	SCT 34 B120 ICE MACHINE	< 0.5 ug/L	15.0	2 Feb 21	KAM
21-A3475	SCT 35 G 1ST FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3476	SCT 36 G100 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3477	SCT 37 F 1ST FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3478	SCT 38 F100 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3479	SCT 39 F121 SINK	2.00 ug/L	15.0	29 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
 @ = Due to sample matrix # = Due to concentration of other analytes
 ! = Due to sample quantity + = Due to internal standard response
 CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 26 Jan 2021
Date Sampled: 20 Jan 2021
Time Sampled: 7:30
Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A3480	SCT 40 F121 SINK	1.73 ug/L	15.0	29 Jan 21	KAM
21-A3481	SCT 41 E 1ST FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3482	SCT 42 E101 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3483	SCT 43 G 2ND FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3484	SCT 44 G216 E SINK	0.51 ug/L	15.0	29 Jan 21	KAM
21-A3485	SCT 45 G216 W SINK	1.17 ug/L	15.0	29 Jan 21	KAM
21-A3486	SCT 46 G200 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3487	SCT 47 G207 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3488	SCT 48 F 2ND FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3489	SCT 49 F200 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM

Page: 5

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 26 Jan 2021
Date Sampled: 20 Jan 2021
Time Sampled: 7:30
Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A3490	SCT 50 F216 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3491	SCT 51 F216 SINK	1.55 ug/L	15.0	29 Jan 21	KAM
21-A3492	SCT 52 F220 W SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3493	SCT 53 F220 E SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3494	SCT 54 E 2ND FLOOR BATHROOM DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3495	SCT 55 E201 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3496	SCT 56 C118 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3497	SCT 57 C118 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3498	SCT 58 C113 SINK	< 0.5 ug/L	15.0	29 Jan 21	KAM
21-A3499	SCT 59 KITCHEN ICE	0.85 ug/L	15.0	2 Feb 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response
CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 3 Feb 2021

Work Order #: 12-4790
 Account #: 019442

JOSH BAUMANN
 RESOURCE TRAINING & SOLUTIONS
 137 23RD ST S
 SARTELL MN 56377

Date Received: 26 Jan 2021
 Date Sampled: 20 Jan 2021
 Time Sampled: 7:30
 Temperature at Receipt: 10.6C

PROJECT NAME: 742 TECH H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
	ICE MACHINE				
21-A3500	SCT 60 WELLNESS CENTER DRINKING FOUNTAIN	< 0.5 ug/L	15.0	29 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
 @ = Due to sample matrix # = Due to concentration of other analytes
 ! = Due to sample quantity + = Due to internal standard response
 CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER